
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 15th September 2025

Table: Average water quality for Kampala Water during the period running 15th September - 21st September 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Luzira Market	Bwaise Kazo	Old Taxi Park	Nabigogo Trading Centre	Kabojja Parents School	Nakawa Market	Mukono Ktoogo Trading Centre	Kisugu Police Station	Maganjo Nalunya	Kasubi Market
Electrical Conductivity (µs/cm)	≤1500	106	160	145	147	145	142	105	148	145	161
pH	6.5-8.5	7.6	7.1	6.9	7.4	6.7	7.2	7.3	6.9	6.9	7.2
Turbidity (NTU)	≤5	0.67	0.77	1.63	2.07	1.20	1.97	1.11	0.68	1.49	0.87
Colour – Apparent (PtCo)	≤15	2	11	11	3	2	8	3	0	0	4
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.40	0.30	0.30	0.20	0.40	0.25	0.50	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.

Wanyera



Julius Wanyera
Ag. Principal Quality Control Officer – KW

Written by:

Enos

Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 25th September 2025

Table: Average water quality for Kampala Water during the period running 15th September - 21st September 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Namugongo JJanda	Masanafu Trading Centre	Buloba PTC	Kansanga Hill P/S	Nakinyuguzi Parents	Nyanama Trading Centre	Namuwo ngo Market	Seeta 12 Miles Village	Kulambiro Pal & Lisa Schools	Mutundwe PAPSCA
Electrical Conductivity (µs/cm)	≤1500	106	145	152	146	151	145	146	106	116	141
pH	6.5-8.5	7.6	6.9	6.9	7.0	7.0	6.7	6.9	7.4	7.6	6.8
Turbidity (NTU)	≤5	0.67	1.49	0.66	1.18	1.34	0.97	2.44	0.73	0.91	1.77
Colour – Apparent (PtCo)	≤15	2	0	5	8	10	0	12	0	7	4
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.30	0.20	0.30	0.30	0.20	0.40	0.30	0.40	0.35
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.

Wanyera

Julius Wanyera
Ag. Principal Quality Control Officer – KW

Written by:

Malambala

Enos Malambala
Quality Assurance Manager – KW

Approved by: