
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 26<sup>th</sup> August 2025

**Table:** Average water quality for Kampala Water during the period running 18<sup>th</sup> August - 24<sup>th</sup> August 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Buloba Bukasa	Ntinda UNEB	Kulambiro Tuba	Kireka Market	M.t Camel Kansanga	Aqua coolers 7 <sup>th</sup> Street	Wantoni Trading Centre	Mengo Bulage	Munyonyo Mawanga zone	Ndejje Kanaaba
Electrical Conductivity (µs/cm)	≤1500	163	124	126	142	136	151	105	157	146	139
pH	6.5-8.5	7.1	6.89	7.3	7.0	7.0	6.9	7.6	7.2	7.0	7.0
Turbidity (NTU)	≤5	1.19	0.98	1.44	1.79	0.95	1.25	0.76	1.42	1.16	1.18
Colour – Apparent (PtCo)	≤15	10	9	14	15	8	11	0	14	9	10
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.3	0.3	0.3	0.4	0.20	0.20	0.35	0.3	0.30	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.

*Wanyera*



Julius Wanyera  
**Ag. Principal Quality Control Officer – KW**

Written by:

*Enos*

Enos Malambala  
**Quality Assurance Manager – KW**

Approved by:

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 26<sup>th</sup> August 2025

**Table:** Average water quality for Kampala Water during the period running 18<sup>th</sup> August - 24<sup>th</sup> August 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Ndeeba Nsiike	Buzinga Market	Wandegeya Police	Nsambya Kirombe	Nakawa Market	Kiswa Primary School	Seeta Market	Uganda Railway Corporation HQTs	Kisugu Police Station	City Abattoir
Electrical Conductivity (µs/cm)	≤1500	148	146	166	144	160	141	100	150	150	150
pH	6.5-8.5	7.0	7.0	7.0	6.6	7.1	7.0	7.6	7.0	7.2	7.0
Turbidity (NTU)	≤5	0.52	1.33	0.63	1.33	1.54	1.10	0.68	1.11	0.80	1.20
Colour – Apparent (PtCo)	≤15	4	12	6	13	12	10	6	10	8	11
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.20	0.20	0.45	0.20	0.30	0.30	0.40	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.

*Wanyera*

Julius Wanyera  
**Ag. Principal Quality Control Officer – KW**

Written by:

*Malambala*

Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: