
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 30th September 2025

Table: Average water quality for Kampala Water during the period running 22nd September - 28th September 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Kairos Schools Bukasa	Mengo Market	Kireka Bbira	Bulaga Police	Maya Trading Centre	Katosi Trading Centre	Bugolobi Market	Mbuya Comboni Sisters	Lugogo Bypass	Kisowera Trading Centre
Electrical Conductivity (µs/cm)	≤1500	141	142	141	143	325	94	106	144	142	109
pH	6.5-8.5	7.1	6.8	6.8	6.9	7.5	7.6	7.3	7.2	6.6	7.3
Turbidity (NTU)	≤5	1.68	1.08	0.85	0.80	0.70	0.49	0.51	3.03	1.31	0.68
Colour – Apparent (PtCo)	≤15	8	6	7	3	3	3	3	15	7	7
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.40	0.20	0.45	0.20	0.25	0.30	0.40	0.45	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.

Wanyera



Julius Wanyera
Ag. Principal Quality Control Officer – KW

Written by:

Malambala

Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 29th September 2025

Table: Average water quality for Kampala Water during the period running 22nd September - 28th September 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Kyebabdo Cntral	Bwaise Mayinja Zone	Ggaba Near Police	Bulenga Trading Centre	Mulago Market	Buganda Royal Institute	Busega Market	Lake Side College Luzira	Kalerwe Market Upper Wing	Bukoto White Flats
Electrical Conductivity (µs/cm)	≤1500	144	144	142	143	140	142	144	106	142	108
pH	6.5-8.5	6.8	7.0	6.6	6.9	7.1	7.2	6.8	7.3	6.8	7.2
Turbidity (NTU)	≤5	0.88	0.97	0.76	0.80	1.51	0.71	1.68	0.55	1.13	1.40
Colour – Apparent (PtCo)	≤15	5	6	9	3	10	7	15	1	6	2
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.20	0.30	0.45	0.40	0.30	0.30	0.50	0.20	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.

Wanyera

Julius Wanyera
Ag. Principal Quality Control Officer – KW

Written by:

Malambala

Enos Malambala
Quality Assurance Manager – KW

Approved by: