

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 08<sup>th</sup> December 2025

**Table:** Average water quality for Kampala Water during the period running 01<sup>st</sup> December - 07<sup>th</sup> December 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Busabala - Kirinda C	Ggaba Market	Kyebando Kisalosalalo Zone	Katanga Mulago	Namasuba ISAMU Foundation School	Kirinya Bukasa	Banda market	Kyambogo UPK	Munyonyo Market	Namboole Stadium Hotel
Electrical Conductivity (µs/cm)	≤1500	145	153	142	142	149	107	143	145	145	99
pH	6.5-8.5	6.8	6.7	7.0	7.0	6.8	6.8	7.2	6.9	6.7	7.4
Turbidity (NTU)	≤5	1.39	0.83	0.89	1.02	1.28	0.68	0.72	0.52	1.29	0.50
Colour – Apparent (PtCo)	≤15	10	5	4	6	10	7	7	4	10	5
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.40	0.30	0.30	0.35	0.40	0.40	0.30	0.40	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by:

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 08<sup>th</sup> December 2025

**Table:** Average water quality for Kampala Water during the period running 01<sup>st</sup> December - 07<sup>th</sup> December 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Fairway Hotel	Bat Valley Primary School	Cooper Complex	Wampewo Primary School	Twinbrook Kindergarten - Bamba	Kisaasi Trading Center	Najjera II	Bwaise Kimombasa Zone	Kabakanjagala Road	Kiira Kasangati Road
Electrical Conductivity (µs/cm)	≤1500	148	147	149	126	147	119	108	147	158	109
pH	6.5-8.5	7.0	6.9	7.3	7.2	7.1	7.4	7.3	6.8	7.1	7.4
Turbidity (NTU)	≤5	1.61	1.01	1.11	1.04	1.17	0.76	0.64	0.96	0.84	0.52
Colour – Apparent (PtCo)	≤15	12	10	9	6	11	4	3	7	4	2
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.25	0.30	0.30	0.30	0.30	0.30	0.30	0.40	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

*Written by:*



Enos Malambala  
**Quality Assurance Manager – KW**

*Approved by:*