

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 15th December 2025

Table: Average water quality for Kampala Water during the period running 08th December - 14th December 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Namungoona Market	Nsambya Hospital	Mengo Hospital Main Gate	Nsambya Kirombe	Rubaga Cathedral Diocesean Office	Kisenyi Bus Terminal	Makindye Kizungu Zone	Ggaba Market	Munyonyo SV	Old Kampala Police Barracks
Electrical Conductivity (µs/cm)	≤1500	142	143	146	145	144	146	143	143	143	146
pH	6.5-8.5	7.0	6.8	7.3	6.8	7.3	7.2	6.7	6.7	6.8	7.2
Turbidity (NTU)	≤5	0.88	1.71	1.07	0.95	0.89	1.11	0.98	1.46	1.50	1.18
Colour – Apparent (PtCo)	≤15	4	13	7	5	5	8	6	11	10	8
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.30	0.40	0.20	0.30	0.20	0.40	0.30	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 15th December 2025

Table: Average water quality for Kampala Water during the period running 08th December - 14th December 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Seguku Katale	Zana Market	Wankulukuku Kabowa	Kireka Market	Bugolobi Sewerage Works	Kiswa Health Center	Kabowa Village	Buddo Booster	Kinawataka Road SV	Bunamwaya Ngobe
Electrical Conductivity (µs/cm)	≤1500	143	144	143	143	143	143	160	148	143	147
pH	6.5-8.5	7.1	7.1	6.7	6.9	6.9	6.8	6.8	7.0	6.8	7.0
Turbidity (NTU)	≤5	0.86	0.69	1.68	1.30	1.19	1.54	1.50	1.46	1.28	1.14
Colour – Apparent (PtCo)	≤15	4	2	13	9	7	10	8	7	9	8
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.25	0.30	0.30	0.40	0.30	0.40	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: