

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 29<sup>th</sup> December 2025

**Table:** Average water quality for Kampala Water during the period running 22<sup>nd</sup> December - 28<sup>th</sup> December 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Buloba Kiwumu Trading Center	Bulaga Police Post	Kasubi Market	Masanafu Trading Center	Namungoona Lower Estate	Oryx Fuel Station Naalya	Kyaliwajjala Trading Center	Bulindo Kiwologoma TC	Bwaise Kazo zone	Kawempe Police Station
Electrical Conductivity (µs/cm)	≤1500	172	172	152	152	152	139	105	113	149	148
pH	6.5-8.5	6.6	6.6	6.8	6.8	6.9	6.9	7.2	7.5	6.7	6.7
Turbidity (NTU)	≤5	0.36	0.34	0.85	0.91	0.85	1.16	0.68	0.62	1.24	1.18
Colour – Apparent (PtCo)	≤15	0	0	6	7	5	6	2	3	10	10
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.30	0.30	0.20	0.30	0.30	0.30	0.30	0.40	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by:

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 29<sup>th</sup> December 2025

**Table:** Average water quality for Kampala Water during the period running 22<sup>nd</sup> December - 28<sup>th</sup> December 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Kanyanya Police Post	Kalerwe Market Upper Wing	Kanyanya Kimali Zone	Kawempe Mbogo Islamic P/S	Makindye Washing Bay	Nsambya Sisters	Seeta Market	Bweyogerere Kazinga Zone	Kansanga Market	Kitintale Market
Electrical Conductivity ( $\mu\text{s}/\text{cm}$ )	$\leq 1500$	155	153	154	153	150	150	108	106	148	103
pH	<b>6.5-8.5</b>	6.8	6.8	6.7	6.8	6.7	6.7	7.4	7.3	6.7	7.1
Turbidity (NTU)	$\leq 5$	1.01	0.93	1.69	1.03	1.37	0.93	1.11	1.22	1.34	0.95
Colour – Apparent (PtCo)	$\leq 15$	9	4	14	8	12	8	9	10	10	8
Escherichia Coliforms (CFU/100m/L)	<b>0</b>	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	<b>0</b>	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	<b>0</b>	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	<b>0.20-0.50</b>	0.40	0.45	0.40	0.30	0.30	0.20	0.30	0.45	0.40	0.30
Total Suspended Solids (mg/L)	<b>0</b>	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

*Written by:*



Enos Malambala  
**Quality Assurance Manager – KW**

*Approved by:*