



Effective date:
19th March 2019

Website Report

Version No.: 1

Revision date:

Report Date: 10th November 2025

Table: Average water quality for Kampala Water during the period running 03rd - 09th November 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Kansanga Rainbow	Makindye Kizungu Zone	Munyonyo Market	Namasuba Kikajjo Zone	Katwe Market	Kanyanya Kimali Zone	Mawanda Road	Luzira Prisons	Bugolobi Resurrection C. O. U	Kirinya SDA Church
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	≤ 1500	145	146	148	152	153	146	145	108	109	107
pH	6.5-8.5	6.7	6.7	6.7	6.9	6.8	6.9	7.2	7.3	7.4	7.6
Turbidity (NTU)	≤ 5	0.85	1.27	1.27	0.93	1.31	1.86	1.41	0.90	0.81	0.66
Colour – Apparent (PtCo)	≤ 15	6	10	10	3	6	15	14	3	4	2
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.35	0.40	0.35	0.30	0.40	0.30	0.45	0.30	0.25	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo

Principal Quality Control Officer – KW

Written by:



Enos Malambala

Quality Assurance Manager – KW

Approved by:



Effective date:
19th March 2019

Website Report

Version No.: 1

Revision date:

Report Date: 10th November 2025

Table: Average water quality for Kampala Water during the period running 03rd - 09th November 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Kiwatule Trading Center	Bukoto White Flats	Najjera II	Nalumunye Jomayi Estates	Katale Lunya	Ggaba Seminary	Buddo Trading Center	Buloba Trading Center	Mukono Market	Arkright Road Seeta
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	≤ 1500	112	111	120	147	149	147	157	160	104	105
pH	6.5-8.5	7.1	7.2	7.5	7.1	6.9	6.9	7.0	7.2	7.7	7.7
Turbidity (NTU)	≤ 5	0.78	0.98	0.82	0.80	1.01	0.98	1.73	1.05	0.70	0.78
Colour – Apparent (PtCo)	≤ 15	7	11	5	4	7	6	14	4	3	4
Escherichia Coliforms (CFU/100mL)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100mL)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100mL)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.35	0.35	0.30	0.40	0.30	0.40	0.40	0.40	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: