



Effective date:
19th March 2019

Website Report

Version No.: 1

Revision date:

Report Date: 13th October 2025

Table: Average water quality for Kampala Water during the period running 06th - 12th October 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Kiswa Health Center	Luzira Kirombe	Buwanuka Tank	Wakiso District Headquaters	Lyna Nursery School	Old Kampala S. S.	Namamve Booster	Namilyango Trading Center	Mukono Dandira	Mukono Kiwugu - Nangwa
Electrical Conductivity (µs/cm)	≤1500	149	106	190	154	149	147	107	103	111	107
pH	6.5-8.5	7.1	6.9	7.1	7.2	7.0	7.2	7.5	7.0	7.8	7.7
Turbidity (NTU)	≤5	0.97	0.81	0.34	1.25	1.28	1.15	0.71	0.74	0.23	0.65
Colour – Apparent (PtCo)	≤15	8	9	5	13	11	12	4	4	1	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.30	0.20	0.20	0.40	0.30	0.45	0.40	0.40	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:



Effective date:
19th March 2019

Website Report

Version No.: 1

Revision date:

Report Date: 13th October 2025

Table: Average water quality for Kampala Water during the period running 06th - 12th October 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Sonde Village	Goma Misindye Zone	Bukasa TC Muyenga	Namagoma Trading Center	Bulenga Booster	Bwaise Industrial Area	Kawempe Mbogo Islamic P/S	Cooper Complex	Ziranumbu Booster	Lake Victoria Serena - Mutungo
Electrical Conductivity (µs/cm)	≤1500	101	107	165	168	119	146	145	146	147	149
pH	6.5-8.5	7.6	7.6	7.3	7.4	7.1	7.2	7.2	7.3	6.7	7.9
Turbidity (NTU)	≤5	0.87	0.72	1.52	1.32	1.22	1.43	1.39	1.05	1.05	1.22
Colour – Apparent (PtCo)	≤15	5	4	11	14	13	10	12	9	10	11
Escherichia Coliforms (CFU/100mL)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100mL)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100mL)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.25	0.45	0.20	0.40	0.20	0.20	0.20	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the water supplied in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: