



Effective date:
19th March 2019

Website Report

Version No.: 1

Revision date:

Report Date: 20th October 2025

Table: Average water quality for Kampala Water during the period running 13th October - 19th October 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Nsambya	Mutundwe	Kiswa Primary School	Kulambiro Pal & Lisa School	Ntinda UNEB	Kireka SDA Primary School	Komamboga Sekanyonyi zone	Mpererwe Market	Nakasero Booster	Kanyanya Booster
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	≤ 1500	159	154	153	161	148	152	144	144	143	146
pH	6.5-8.5	6.8	6.8	7.1	7.1	6.8	7.0	6.8	7.1	7.1	6.9
Turbidity (NTU)	≤ 5	0.31	0.50	0.83	1.28	1.17	1.58	0.79	0.80	1.10	0.54
Colour – Apparent (PtCo)	≤ 15	3	4	5	13	10	14	8	8	10	4
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.25	0.30	0.40	0.50	0.20	0.25	0.25	0.30	0.35
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National standards for treated potable water. The water is therefore safe for consumption.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: