



Effective date:  
19<sup>th</sup> March 2019

Website Report

Version No.: 1

Revision date:

**Report Date:** 24<sup>th</sup> November 2025

**Table:** Average water quality for Kampala Water during the period running 17<sup>th</sup> November - 23<sup>rd</sup> November 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Munyonyo SV	Ggaba Market	Aqua Coolers Ltd - 7th Street	City Abattoir	Bulindo Kiwologoma TC	Kansanga Hill Primary School	Lubowa Police Post	Ndeeba Nsiike Zone	Kyengera Trading Center	Mutundwe PAPSCA
Electrical Conductivity (µs/cm)	<b>≤1500</b>	150	137	147	145	105	142	139	146	147	150
pH	<b>6.5-8.5</b>	6.7	6.8	7.2	7.2	7.5	6.9	6.8	6.8	7.1	6.9
Turbidity (NTU)	<b>≤5</b>	1.08	1.70	1.02	1.64	0.80	0.73	1.23	1.33	1.02	0.55
Colour – Apparent (PtCo)	<b>≤15</b>	4	7	10	11	4	8	10	11	8	0
Escherichia Coliforms (CFU/100m/L)	<b>0</b>	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	<b>0</b>	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	<b>0</b>	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	<b>0.20-0.50</b>	0.50	0.30	0.30	0.30	0.30	0.30	0.40	0.30	0.30	0.40
Total Suspended Solids (mg/L)	<b>0</b>	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by:



Effective date:  
19<sup>th</sup> March 2019

Website Report

Version No.: 1

Revision date:

**Report Date:** 24<sup>th</sup> November 2025

**Table:** Average water quality for Kampala Water during the period running 17<sup>th</sup> November - 23<sup>rd</sup> November 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Fire Brigade Headquaters	Kamwokya Community	Kisenyi II Kakajjo Zone	Katanga Soweto Zone	Namayiba Bus Terminal	Bweyogerere Kazinga Zone	Bwaise Market	Kagoma Islamic P/S	Maganjo Nalunya	Katale Lunya
Electrical Conductivity ( $\mu\text{s}/\text{cm}$ )	<b><math>\leq 1500</math></b>	145	146	145	146	145	154	147	147	146	139
pH	<b>6.5-8.5</b>	7.2	7.1	7.1	7.1	7.1	6.9	6.8	6.8	6.8	6.8
Turbidity (NTU)	<b><math>\leq 5</math></b>	1.27	1.42	1.41	1.42	1.45	1.43	1.39	1.25	1.36	1.07
Colour – Apparent (PtCo)	<b><math>\leq 15</math></b>	4	5	5	8	6	10	10	7	9	9
Escherichia Coliforms (CFU/100mL)	<b>0</b>	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100mL)	<b>0</b>	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100mL)	<b>0</b>	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	<b>0.20-0.50</b>	0.50	0.30	0.20	0.30	0.20	0.30	0.30	0.30	0.30	0.40
Total Suspended Solids (mg/L)	<b>0</b>	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: