



Effective date:  
19<sup>th</sup> March 2019

Website Report

Version No.: 1

Revision date:

**Report Date:** 27<sup>th</sup> October 2025

**Table:** Average water quality for Kampala Water during the period running 20<sup>th</sup> October - 26<sup>th</sup> October 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Mengo Bulange	Rubaga Road SV1332	Buganda Royal Institute	Kisenyi I Musajjalumbwa Road	Ericcson House Nakasero	Namamve Booster	Mukono UCU	Nama Trading Center	Seeta Market	Bukerere Trading Center
Electrical Conductivity (µs/cm)	<b>≤1500</b>	144	145	144	145	147	106	109	109	106	110
pH	<b>6.5-8.5</b>	7.0	7.2	7.1	7.2	7.2	7.3	7.5	7.6	7.6	7.6
Turbidity (NTU)	<b>≤5</b>	1.01	0.67	0.46	0.51	1.06	0.72	0.82	0.69	0.82	1.09
Colour – Apparent (PtCo)	<b>≤15</b>	10	4	3	2	9	5	6	4	4	9
Escherichia Coliforms (CFU/100m/L)	<b>0</b>	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	<b>0</b>	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	<b>0</b>	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	<b>0.20-0.50</b>	0.30	0.40	0.30	0.30	0.30	0.20	0.40	0.20	0.30	0.30
Total Suspended Solids (mg/L)	<b>0</b>	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by:



Effective date:  
19<sup>th</sup> March 2019

Website Report

Version No.: 1

Revision date:

**Report Date:** 27<sup>th</sup> October 2025

**Table:** Average water quality for Kampala Water during the period running 20<sup>th</sup> October - 26<sup>th</sup> October 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Hill View Estates Sonde	Namboole Stadium Hotel	Mutungo Trading Center	Lugogo Bypass	Arua Park	Bwaise Central Zone	City High School Kololo	Kalerwe Market Upper Wing	Makerere Kivulu	Kawempe Ssebagala
Electrical Conductivity (µs/cm)	≤1500	107	109	112	151	150	150	150	150	152	150
pH	6.5-8.5	7.6	7.7	7.3	6.8	6.7	6.8	7.1	6.8	6.9	6.8
Turbidity (NTU)	≤5	0.54	0.51	0.81	1.25	1.11	0.83	0.79	0.85	0.73	0.98
Colour – Apparent (PtCo)	≤15	3	2	5	10	10	6	4	7	5	8
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.20	0.40	0.30	0.20	0.20	0.40	0.30	0.20	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water. The water is therefore safe for consumption.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: