
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 09th February 2026

Table: Average water quality for Kampala Water during the period running 02nd February - 08th February 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		MUBS Nakawa	Luzira Prisons	Bweyogerere Market	Nakawa Market	Katale Lunya	Kagoma Islamic P/S	Matuga Market	Wampewo Primary School	Kabowa Village	Kibuye Market
Electrical Conductivity (µs/cm)	≤1500	144	142	103	143	149	142	141	107	374	371
pH	6.5-8.5	7.1	7.0	7.7	7.1	7.8	6.9	7.3	7.4	7.5	7.0
Turbidity (NTU)	≤5	1.40	1.84	1.16	1.88	0.71	0.39	1.33	1.05	1.02	0.61
Colour – Apparent (PtCo)	≤15	10	13	10	13	8	0	5	5	5	3
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0	0	0	0	0	0	0	0	0	0
Total Suspended Solids (mg/L)	0	0.40	0.40	0.35	0.30	0.20	0.35	0.40	0.50	0.30	0.30

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 09th February 2026

Table: Average water quality for Kampala Water during the period running 02nd February - 08th February 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Namasuba St. Elizabeth	Ntinda Ministers' Village	Kiira Kasangati Road	Najjera II	Kisaasi Trading Center	Kansanga Rainbow	Nsambya St. Peter's School	Salaama Road	Munyonyo SV	Joggo Trading Center
Electrical Conductivity (µs/cm)	≤1500	148	126	103	104	119	150	149	159	149	136
pH	6.5-8.5	6.8	8.2	7.7	7.7	7.7	6.9	7.1	6.9	6.9	7.2
Turbidity (NTU)	≤5	0.70	1.85	1.39	1.20	1.44	1.30	0.86	0.65	1.18	0.53
Colour – Apparent (PtCo)	≤15	0	13	10	9	13	10	4	0	9	2
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0	0	0	0	0	0	0	0	0	0
Total Suspended Solids (mg/L)	0	0.30	0.20	0.35	0.30	0.35	0.20	0.40	0.20	0.30	0.30

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: