
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 09th March 2026

Table: Average water quality for Kampala Water during the period running 02nd March - 08th March 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Wandegeya Market	Kawempe Holy Family	Bwaise Kimombasa Zone	Busabala Road, Masajja TC	Bweyogerere Market	Mukono Market	Arkrigh Road Seeta - Near Hill Top P/S	Sonde Trading Center	Kirinya Bukasa	Makindye Kizungu Zone
Electrical Conductivity (µs/cm)	≤1500	145	151	147	141	141	104	103	104	104	142
pH	6.5-8.5	6.9	6.9	7.1	7.1	7.2	7.5	7.6	7.6	7.7	7.2
Turbidity (NTU)	≤5	1.28	1.70	1.72	0.66	1.98	0.92	0.84	0.63	0.63	1.82
Colour – Apparent (PtCo)	≤15	12	15	11	4	14	11	7	7	8	8
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.20	0.30	0.30	0.30	0.35	0.55	0.50	0.30	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 09th March 2026

Table: Average water quality for Kampala Water during the period running 02nd March - 08th March 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Nsambya Hospital	Munyonyo Market	Ggaba Seminary	Mengo Bulange	Masanafu Trading Center	Rubaga Cathedral Diocesan Office	Bunamwaya Kitebi	Fairway Hotel	Nakasero Market Lower Wing	Kakiri Police Division
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	≤ 1500	143	137	145	154	144	151	152	150	152	170
pH	6.5-8.5	7.2	7.1	7.1	7.2	6.9	7.0	6.9	7.1	7.3	7.1
Turbidity (NTU)	≤ 5	1.60	1.00	1.78	0.73	1.71	0.97	1.70	1.43	0.68	0.91
Colour – Apparent (PtCo)	≤ 15	8	12	10	9	10	6	10	11	8	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.40	0.25	0.30	0.30	0.30	0.40	0.25	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date: