
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 13th April 2026

Table: Average water quality for Kampala Water during the period running 06th April - 12th April 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Namamve Booster	Mukono Health Center IV	Arkright Road Seeta - Near Hill Top P/S	Mukono UCU	Sonde Trading Center	Joggo Trading Center	All Saints' Cathedral Nakasero	Wandegeya Market	Bat Valley Primary School	Kanjokya Street SV
Electrical Conductivity (µs/cm)	≤1500	103	101	101	101	102	101	124	137	140	138
pH	6.5-8.5	7.3	7.3	7.7	7.7	7.8	7.7	7.6	7.6	7.5	7.3
Turbidity (NTU)	≤5	1.17	1.12	0.92	0.98	0.88	0.91	1.59	1.23	1.60	1.55
Colour – Apparent (PtCo)	≤15	8	11	8	6	6	7	6	6	14	9
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.35	0.35	0.35	0.30	0.35	0.45	0.40	0.30	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 13th April 2026

Table: Average water quality for Kampala Water during the period running 06th April - 12th April 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Kyambogo Primary School	Kitukutwe Trading Center	Najjera II	Bukoto White Flats	Komamboga Kwata Zone	Lungujja - Kitunzi	Masanafu Trading Center	Namasuba Market	Bunamwaya Kitebi	Munyonyo Market
Electrical Conductivity (µs/cm)	≤1500	140	103	102	132	104	142	143	142	142	138
pH	6.5-8.5	7.2	7.6	7.8	7.3	7.3	7.1	7.0	6.9	7.0	7.1
Turbidity (NTU)	≤5	0.93	0.90	0.93	1.35	0.87	1.55	1.41	1.42	1.36	1.48
Colour – Apparent (PtCo)	≤15	2	0	4	5	2	8	9	9	12	12
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.35	0.30	0.35	0.30	0.30	0.30	0.40	0.30	0.35	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by: