
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 16th February 2026

Table: Average water quality for Kampala Water during the period running 09th February - 15th February 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Shell at Grand Imperial Hotel	Bwaise Kusatu zone	Makerere Primary School	United Christian Center Church - Kikoni	Katanga Near JB Girls' Hostel	Kisoga Trading Center	Katosi Trading Center	Kabanyoro Trading Center	Gayaza Trading Center	Kasangati Bulamu zone
Electrical Conductivity (µs/cm)	≤1500	140	141	143	142	141	93	94	103	103	97
pH	6.5-8.5	6.9	7.1	7.0	7.0	7.0	7.4	7.4	7.2	7.6	6.9
Turbidity (NTU)	≤5	1.68	1.46	1.53	1.29	1.75	0.50	0.28	1.18	1.05	0.51
Colour – Apparent (PtCo)	≤15	12	11	9	8	12	1	0	7	6	4
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.40	0.50	0.30	0.40	0.25	0.30	0.25	0.20	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of water supplied through the distribution network complied with national standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 16th February 2026

Table: Average water quality for Kampala Water during the period running 09th February - 15th February 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Matuga Kyogogwa Village	5th Street - Kibira Road V-244	Kinawataka Road SV	Old Kampala S. S.	Kisenyi Bus Terminal	Kitante Hill School	Namungoona Lower Estate	Kakiri Police Division	Namusera Trading Center	Goma Misindye Zone
Electrical Conductivity (µs/cm)	≤1500	142	148	104	142	143	142	148	187	168	104
pH	6.5-8.5	6.9	7.0	8.0	7.2	7.4	7.3	7.0	6.8	6.7	7.3
Turbidity (NTU)	≤5	1.78	1.77	1.70	1.54	1.74	1.90	1.55	0.87	0.46	1.43
Colour – Apparent (PtCo)	≤15	14	8	12	12	13	11	8	5	3	10
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.60	0.30	0.30	0.20	0.30	0.50	0.25	0.30	0.25
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of water supplied through the distribution network complied with national standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: