
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 16<sup>th</sup> March 2026

**Table: Average water quality for Kampala Water during the period running 09<sup>th</sup> March - 15<sup>th</sup> March 2026**

Parameter	National Standard For Potable Water	Monitoring Points									
		Old Kampala S. S.	Rubaga Kabusu	Namungoona Lower Estate	Kisenyi III Kiti Zone	Namilyango Trading Center	Goma Misindye Zone	Wabulege - Namuyenje Village	Mukono Dandira	Sonde Village	Namamve Booster
Electrical Conductivity (µs/cm)	≤1500	137	141	139	136	101	101	101	101	102	102
pH	6.5-8.5	7.2	7.3	7.2	7.2	7.8	7.9	7.9	7.9	7.9	7.9
Turbidity (NTU)	≤5	1.40	1.39	0.68	0.69	0.52	0.39	0.53	0.44	0.24	0.44
Colour – Apparent (PtCo)	≤15	7	9	9	4	5	4	3	2	6	4
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.35	0.30	0.30	0.30	0.35	0.30	0.40	0.50	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physicochemical and bacteriological quality of water supplied through the distribution network complied with national standards for treated potable water.





Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Ag. Sen. Manager Quality Assurance – KW**

Approved by:

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 16<sup>th</sup> March 2026

**Table: Average water quality for Kampala Water during the period running 09<sup>th</sup> March - 15<sup>th</sup> March 2026**

Parameter	National Standard For Potable Water	Monitoring Points									
		Ggaba Market	Nsambya Xavier	Kigo Lunya	Ndejje Kanyanya Zone	Ndejje Ziranumbu Village	Ngombere Trading Center	Portbell market	5th Street - Kibira Road V-244	St. Banarbas P/S - Kisugu	Uganda Management Institute
Electrical Conductivity (µs/cm)	≤1500	133	131	134	141	138	91	133	141	139	145
pH	6.5-8.5	7.9	7.8	7.4	7.3	7.3	7.5	6.9	7.0	7.0	7.0
Turbidity (NTU)	≤5	0.83	0.81	0.78	1.57	0.84	0.43	1.32	1.53	1.00	1.20
Colour – Apparent (PtCo)	≤15	6	6	6	12	9	3	3	2	4	5
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.30	0.30	0.30	0.40	0.40	0.35	0.30	0.35	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physicochemical and bacteriological quality of water supplied through the distribution network complied with national standards for treated potable water.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Ag. Sen. Manager Quality Assurance – KW**

Approved by: