
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 18th May 2026

Table: Average water quality for Kampala Water during the period running 11th May - 17th May 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Cooper Complex	Kisenyi III Kiti Zone	Kitante Hill School	Shell at Grand Imperial Hotel	Uganda Management Institute	American Embassy Nsambya	Bukasa TC Muyenga	Kasubi Luby	Namungoona Lower Estate	Kawempe Mbogo Islamic P/S
Electrical Conductivity (µs/cm)	≤1500	133	133	134	129	129	133	133	139	133	134
pH	6.5-8.5	7.6	7.6	7.7	7.6	7.8	7.7	7.6	7.6	7.7	7.5
Turbidity (NTU)	≤5	0.86	0.89	0.84	0.88	0.95	0.88	1.17	1.17	1.08	1.84
Colour – Apparent (PtCo)	≤15	8	9	8	8	9	8	10	11	10	13
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.35	0.50	0.40	0.40	0.35	0.30	0.50	0.30	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 18th May 2026

Table: Average water quality for Kampala Water during the period running 11th May - 17th May 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Makerere Primary School	Mawanda Road - Denaro Apartment	Kanyanya Police Post	Lyna Nursery School	Mengo Hospital Main Gate	Rubaga Cathedral Diocesan Office	Bugolobi Flats - Block 26	Mbuya Comboni Sisters	Katwe Market	Katale Lunya
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	≤ 1500	134	135	134	120	133	120	132	129	134	137
pH	6.5-8.5	7.5	7.7	7.6	7.6	7.5	7.7	7.7	7.8	7.6	7.6
Turbidity (NTU)	≤ 5	1.37	1.36	1.41	1.46	1.36	1.16	0.95	0.90	1.28	1.08
Colour – Apparent (PtCo)	≤ 15	8	6	10	13	12	8	4	6	14	12
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.40	0.40	0.30	0.40	0.40	0.35	0.30	0.30	0.50
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by: