
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 19th January 2026

Table: Average water quality for Kampala Water during the period running 12th January - 18th January 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Nansana Market	Wakiso District Headquarters	Wakiso Kayunga Ward	Kyambogo Primary School	Kiira Kasangati Road	Najjera I	Jomayi Estates Nabusugwe	Ndejje Kanyanya Zone	Kigo Mutungo market	Makindye Washing Bay
Electrical Conductivity (µs/cm)	≤1500	153	153	172	152	103	102	107	148	156	150
pH	6.5-8.5	7.0	7.2	6.5	6.6	7.3	7.6	7.5	6.9	6.7	6.7
Turbidity (NTU)	≤5	1.37	1.68	0.39	0.57	0.97	1.33	0.88	1.95	1.75	1.99
Colour – Apparent (PtCo)	≤15	5	14	5	1	4	9	6	11	12	12
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.35	0.35	0.30	0.30	0.30	0.30	0.30	0.40	0.30	0.35
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 19th January 2026

Table: Average water quality for Kampala Water during the period running 12th January - 18th January 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Kansanga Mt. Carmel	Ggaba Market	Nateete Market	Mutundwe Kisigula	Wankulukuku Market	Wandegeya Police Station	Kisenyi Bus Terminal	Namungoona Market	Mengo Hospital Main Gate	Usafi Market
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	≤ 1500	149	148	141	156	151	145	149	153	147	149
pH	6.5-8.5	6.8	6.7	7.1	7.0	7.1	7.0	7.0	6.8	7.3	7.2
Turbidity (NTU)	≤ 5	1.10	1.33	0.51	0.88	0.92	0.80	1.50	1.49	0.69	1.24
Colour – Apparent (PtCo)	≤ 15	8	8	0	0	3	10	13	15	5	8
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.35	0.20	0.30	0.35	0.30	0.30	0.30	0.40	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: