
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 20th April 2026

Table: Average water quality for Kampala Water during the period running 13th April - 19th April 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Kasubi Market	Old Taxi Park	Kamwokya Market	City High School Kololo	Nakulabye Market	Police Training School Kibuli	AM Luzira Water Village	Bwaise Kusatu zone	Kawempe Mbogo Islamic P/S	Kisenyi Bus Terminal
Electrical Conductivity (µs/cm)	≤1500	140	139	144	138	131	128	107	150	137	151
pH	6.5-8.5	7.1	7.1	7.2	7.1	7.0	7.1	7.9	7.2	7.3	7.3
Turbidity (NTU)	≤5	1.26	1.39	1.51	2.11	1.89	1.83	0.96	1.17	1.35	1.48
Colour – Apparent (PtCo)	≤15	14	12	8	12	10	8	3	7	11	11
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.45	0.30	0.40	0.30	0.40	0.30	0.30	0.30	0.25	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 20th April 2026

Table: Average water quality for Kampala Water during the period running 13th April - 19th April 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Usafi Market	Ggaba Market	Makindye Washing Bay	Busabala Road Clinic	Lake Victoria Serena - Mutungo	Ndejje Kanyanya Zone	Seguku Katale	Buddo Trading Center	Wakiso Kayunga Ward	Kasengejje Road
Electrical Conductivity (µs/cm)	≤1500	123	149	146	143	138	146	146	141	195	163
pH	6.5-8.5	7.1	7.0	7.1	6.9	7.0	7.0	7.0	6.9	7.0	6.7
Turbidity (NTU)	≤5	1.11	1.51	1.61	1.41	1.71	1.38	1.58	1.17	0.83	1.04
Colour – Apparent (PtCo)	≤15	9	13	12	10	14	10	7	7	9	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.30	0.20	0.35	0.40	0.30	0.30	0.20	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by: