
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 23rd February 2026

Table: Average water quality for Kampala Water during the period running 16th February - 22nd February 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Aqua Coolers Ltd - 7th Street	Kamwokya Community	Katanga Soweto Zone	Kololo York Terrace Junction SV	Nakasero Primary School	Old Taxi Park	Bakuli Market	Naalya L.C. 1	Namugongo Jjanda	Green Hill Academy Buwate
Electrical Conductivity (µs/cm)	≤1500	139	137	137	141	136	142	134	116	103	104
pH	6.5-8.5	6.8	6.8	6.8	6.8	6.9	6.7	7.3	7.2	7.4	7.7
Turbidity (NTU)	≤5	1.61	1.70	1.81	1.89	1.50	1.12	1.97	1.83	0.95	1.13
Colour – Apparent (PtCo)	≤15	6	8	9	11	5	4	15	5	3	2
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.25	0.30	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 23rd February 2026

Table: Average water quality for Kampala Water during the period running 16th February - 22nd February 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Ntinda Old Market	Kyaliwajjala Trading Center	Zana Market	Seguku Katale	Mutundwe Kisigula	Kigo Lunya	Makindye Washing Bay	Seeta 12 Miles Village	Namawojjolo Buligobe	Bugolobi Hospital
Electrical Conductivity (µs/cm)	≤1500	119	104	139	140	138	140	149	131	140	105
pH	6.5-8.5	7.5	7.6	6.9	7.0	7.4	7.1	7.3	8.2	8.5	7.6
Turbidity (NTU)	≤5	1.80	1.08	1.42	1.59	0.76	1.60	1.55	1.21	1.78	1.14
Colour – Apparent (PtCo)	≤15	8	3	13	7	4	13	3	7	8	15
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.30	0.20	0.30	0.20	0.20	0.30	0.25	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: