
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 26th January 2026

Table: Average water quality for Kampala Water during the period running 19th January - 25th January 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Buloba Bukasa TC	Buloba Kiwumu TC	Wakiso Mpunga Ward	Mengo Kisenyi, Nanyonzi Zone	Lungujja - Kosovo	Kyaliwajjala Trading Center	Namugongo Jjanda	Bulindo Kiwologoma TC	Green Hill Academy Buwate	Kitemu Nsangi
Electrical Conductivity (µs/cm)	≤1500	152	153	153	147	148	98	106	93	103	317
pH	6.5-8.5	6.8	6.9	7.1	6.8	6.8	7.6	7.8	7.6	7.7	7.8
Turbidity (NTU)	≤5	1.20	1.34	1.17	0.82	0.76	0.69	0.99	0.65	0.62	1.12
Colour – Apparent (PtCo)	≤15	11	8	8	0	0	11	10	3	2	14
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.35	0.40	0.30	0.30	0.25	0.30	0.30	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 26th January 2026

Table: Average water quality for Kampala Water during the period running 19th January - 25th January 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Hossanna Estates - Kyambazi	Katale Mayanja	Lubowa Police Post	Ndeeba Kasumba Zone	Mugwanya Summit College - Kyengera	Kansanga Hill Primary School	Katanga Soweto Zone	Kamwokya Community	City Abattoir	Mpererwe Market
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	≤ 1500	321	155	157	146	145	155	162	162	145	103
pH	6.5-8.5	7.7	6.8	7.0	6.9	7.2	7.1	7.1	7.0	7.4	7.4
Turbidity (NTU)	≤ 5	1.71	1.14	1.29	1.85	1.54	1.62	1.68	1.32	1.02	0.77
Colour – Apparent (PtCo)	≤ 15	14	12	7	14	11	7	10	8	6	9
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.35	0.30	0.30	0.30	0.30	0.40	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: