
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 27th April 2026

Table: Average water quality for Kampala Water during the period running 20th April - 26th April 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Kasokoso Community PSP	Bweyogerere Butto	Kinawataka Police Post	Bugolobi Hospital	Kulambiro Pal & Lisa School	Ntinda Old Market	Aqua Coolers Ltd - 7th Street	Fire Brigade Headquarters	Lubiri High School	Nakasero Primary School
Electrical Conductivity (µs/cm)	≤1500	146	144	145	146	146	146	142	144	146	146
pH	6.5-8.5	6.7	6.7	6.6	6.7	6.7	6.8	7.1	7.1	7.2	7.1
Turbidity (NTU)	≤5	1.34	1.26	0.94	1.12	1.67	1.32	1.93	0.73	1.49	1.86
Colour – Apparent (PtCo)	≤15	8	8	4	9	11	11	4	0	8	14
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.25	0.30	0.35	0.30	0.35	0.25	0.30	0.30	0.25
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 27th April 2026

Table: Average water quality for Kampala Water during the period running 20th April - 26th April 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Bunga market	Munyonyo Mawanga Zone	Nakinyuguzi Trading Center	Bakuli Market	Kisugu Police Station	Bwaise Kazo zone	Kagoma Islamic P/S	Kawempe Police Station	American Embassy Nsambya	Mukono Health Center IV
Electrical Conductivity (µs/cm)	≤1500	145	144	142	156	141	138	134	134	125	99
pH	6.5-8.5	7.2	7.2	7.1	6.8	7.1	6.8	7.0	7.0	7.1	7.5
Turbidity (NTU)	≤5	1.39	1.78	1.91	1.53	1.59	1.78	1.77	1.11	0.95	0.86
Colour – Apparent (PtCo)	≤15	10	13	15	12	7	4	5	4	2	2
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.20	0.40	0.30	0.30	0.30	0.25	0.30	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by: