
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 30th March 2026

Table: Average water quality for Kampala Water during the period running 23rd March - 29th March 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Namamve Booster	Namilyango Trading Center	Goma Misindye Zone	Wabulege - Namuyenje Village	Naalya Estate	Bwaise St. Kizito	Mpererwe Market	Kyebando Nsooba	Ericcson House Nakasero	Wandegeya Police Station
Electrical Conductivity (µs/cm)	≤1500	103	102	100	99	103	139	140	144	139	143
pH	6.5-8.5	7.6	7.6	7.7	7.7	7.8	7.6	7.0	7.0	7.0	7.0
Turbidity (NTU)	≤5	1.47	1.31	0.83	0.80	0.79	1.03	1.47	1.76	1.89	1.49
Colour – Apparent (PtCo)	≤15	8	10	4	5	4	6	11	9	8	10
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.35	0.30	0.35	0.30	0.35	0.40	0.30	0.30	0.30	0.35
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of water supplied through the distribution network complied with national standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 30th March 2026

Table: Average water quality for Kampala Water during the period running 23rd March - 29th March 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Arua Park	Speke Hotel	Bwaise Central Zone	Kalerwe Market Lower Wing	Namasuba Kikajjo Zone	All Saints' Cathedral Nakasero	Makerere College School	Kulambiro Pal & Lisa School	Kyaliwajjala Trading Center	Green Hill Academy Buwate
Electrical Conductivity (µs/cm)	≤1500	134	149	146	131	139	132	139	151	101	102
pH	6.5-8.5	6.6	6.9	6.9	6.9	7.0	7.3	6.9	6.7	7.1	7.3
Turbidity (NTU)	≤5	1.56	1.88	1.45	1.78	1.07	1.32	1.89	1.19	1.21	1.08
Colour – Apparent (PtCo)	≤15	4	4	7	10	7	9	8	5	6	2
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0	0	0	0	0	0	0	0	0	0
Total Suspended Solids (mg/L)	0	0.30	0.25	0.40	0.30	0.20	0.40	0.30	0.30	0.30	0.40

Remarks

The physicochemical and bacteriological quality of water supplied through the distribution network complied with national standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW