
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 02nd February 2026

Table: Average water quality for Kampala Water during the period running 26th January - 01st February 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Bugolobi Resurrection C. O. U	Mutungo Zone 3	Kasokoso Kiganda PSP	Namboole Trading Center	Bweyogerere Butto	Kirinya SDA Church	Nonve Sump	Nakasero Primary School	Lumumba Avenue - Lumumba Lane Junction SV	Bakuli Market
Electrical Conductivity (µs/cm)	≤1500	101	90	106	104	106	107	203	142	143	146
pH	6.5-8.5	6.9	7.1	7.5	7.6	7.7	7.2	7.1	6.7	6.7	7.0
Turbidity (NTU)	≤5	1.25	0.81	1.59	0.86	1.47	0.94	1.02	1.02	0.80	1.23
Colour – Apparent (PtCo)	≤15	8	0	7	0	10	1	3	6	1	2
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.30	0.25	0.40	0.30	0.30	0.25	0.20	0.30	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 02nd February 2026

Table: Average water quality for Kampala Water during the period running 26th January - 01st February 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Namungoona Market	Mukono UCU	Kisowera Trading Centre	Mukono Budugala TC	Seeta Market	Bukerere Trading Center	Kalerwe Market Upper Wing	Bwaise Kimalimali Zone	Katwe Kinyolo	Nakulabye Market
Electrical Conductivity (µs/cm)	≤1500	146	102	95	101	112	114	144	143	102	143
pH	6.5-8.5	7.1	7.7	7.7	7.7	7.8	7.7	7.2	7.2	7.0	7.3
Turbidity (NTU)	≤5	0.99	1.77	1.85	1.78	1.20	1.78	1.82	1.39	1.07	1.25
Colour – Apparent (PtCo)	≤15	8	13	14	15	6	13	13	14	3	4
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.35	0.30	0.30	0.40	0.35	0.40	0.30	0.20	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: