
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 04th May 2026

Table: Average water quality for Kampala Water during the period running 27th April - 03rd May 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Lugogo Bypass	Banda Market	Kinawataka Road SV	Naguru Police Barracks	Makerere College School	Kawala TC Near Police	Mengo Hospital Main Gate	Buganda Royal Institute	Yowanamaria (WSP 47 11C)	Rubaga Nabunya
Electrical Conductivity (µs/cm)	≤1500	106	98	133	134	143	135	135	133	133	146
pH	6.5-8.5	7.3	7.6	7.2	7.2	6.9	7.0	7.0	6.9	7.0	7.0
Turbidity (NTU)	≤5	0.79	0.67	1.84	1.94	1.80	1.16	1.08	1.37	1.47	1.78
Colour – Apparent (PtCo)	≤15	0	1	5	8	12	3	4	6	1	2
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.30	0.20	0.30	0.50	0.30	0.20	0.40	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 04th May 2026

Table: Average water quality for Kampala Water during the period running 27th April - 03rd May 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Hill View Estates Sonde	Namugongo Sonde	Bukerere Trading Center	Kiira Trading Center	Namamve Booster	Mukono Ntawo Trading Center	Kisowera Trading Centre	Hotel Africana	Makerere Kivulu	Arua Park
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	≤ 1500	100	99	99	99	99	97	99	130	125	118
pH	6.5-8.5	7.3	7.3	7.4	7.5	7.6	7.7	7.7	7.5	7.3	7.4
Turbidity (NTU)	≤ 5	1.25	1.34	1.35	1.36	1.20	1.27	0.84	1.22	1.08	1.41
Colour – Apparent (PtCo)	≤ 15	12	13	13	13	12	12	10	12	10	12
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.35	0.30	0.30	0.40	0.40	0.30	0.40	0.40	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by: