
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 06th April 2026

Table: Average water quality for Kampala Water during the period running 30th March - 05th April 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Wankulukuku Market	Katale Mayanja	Zana Market	Aqua Coolers Ltd - 7th Street	City Abattoir	Kamwokya Community	St. Paul's C.O.U Kyebando	Kyanja Trading Center	Mukono UCU	Kisowera Trading Centre
Electrical Conductivity (µs/cm)	≤1500	149	146	142	140	138	116	111	112	101	101
pH	6.5-8.5	7.1	7.3	7.4	7.1	6.9	7.1	6.9	6.9	7.6	7.8
Turbidity (NTU)	≤5	1.04	1.02	0.92	0.95	0.87	1.09	1.41	1.20	0.74	1.28
Colour – Apparent (PtCo)	≤15	4	7	7	5	7	7	8	7	5	7
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.20	0.20	0.25	0.40	0.40	0.25	0.30	0.35	0.35
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of water supplied through the distribution network complied with national standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 06th April 2026

Table: Average water quality for Kampala Water during the period running 30th March - 05th April 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Kirinya Bukasa	Kireka Market	Kabalega Crescent - Luzira	Nsambya Hospital	Kansanga Market	Ggaba Seminary	MUBS Nakawa	Mawanda Road - Denaro Apartment	St. Denis Sebugwawo Church Konge Lukuli	Bwaise St. Kizito
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	≤ 1500	142	140	168	141	141	141	145	116	144	150
pH	6.5-8.5	6.9	6.8	6.7	7.1	7.0	7.1	7.0	7.2	6.9	7.0
Turbidity (NTU)	≤ 5	1.28	1.00	0.93	1.10	0.92	1.35	1.24	1.25	0.98	1.05
Colour – Apparent (PtCo)	≤ 15	8	11	7	8	3	6	2	3	0	4
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.20	0.20	0.40	0.30	0.50	0.40	0.40	0.35
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of water supplied through the distribution network complied with national standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by: