

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 01st June 2026

Table: Average water quality for Kampala Water during the period running 25th May - 31st May 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Namamve Booster	Seeta Market	Mukono Ntawo Trading Center	Kisowera Trading Centre	Kawala TC Near Police	Buganda Royal Institute	Kisenyi III Kiti Zone	Sixth Street Roundabout SV	Kasengejje Road	Bulenga Trading Center
Electrical Conductivity (µs/cm)	≤1500	99	98	99	99	132	131	136	139	167	140
pH	6.5-8.5	7.4	7.5	7.9	7.9	7.4	7.4	7.4	7.6	6.9	7.0
Turbidity (NTU)	≤5	1.09	1.11	1.74	0.81	1.83	1.72	1.51	1.85	0.55	0.85
Colour – Apparent (PtCo)	≤15	5	4	4	0	14	13	4	13	0	3
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.35	0.30	0.30	0.35	0.25	0.30	0.30	0.55	0.25	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 01st June 2026

Table: Average water quality for Kampala Water during the period running 25th May - 31st May 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Ntenjeru Trading Center	Kisoga Trading Center	Ggonve Trading Center	Katosi Trading Center	Ngombere Trading Center	Nonve Sump	Buwanuka Tank	Nadangira Tank	Mulago Tank Upper	Mukono Budugala Trading Center
Electrical Conductivity (µs/cm)	≤1500	93	93	94	93	94	202	203	203	103	99
pH	6.5-8.5	7.4	7.4	7.4	7.4	7.4	7.1	7.2	7.2	7.7	7.9
Turbidity (NTU)	≤5	0.38	0.42	0.39	0.48	0.50	0.59	0.55	0.41	0.83	0.85
Colour – Apparent (PtCo)	≤15	4	4	4	4	4	0	0	0	4	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.20	0.20	0.30	0.20	0.30	0.35	0.30	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by: