

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 08th June 2026

Table: Average water quality for Kampala Water during the period running 01st June - 07th June 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Lungujja - Good Star Nursery School	Lungujja - Makamba	Masanafu Trading Center	Namungoona Booster	Albert Cook Road SV	Kyambogo Booster	Mengo Bulange	Mengo Kisenyi, Nanyonzi Zone	Yowanamaria (WSP 47 11C)	Hotel Africana
Electrical Conductivity (µs/cm)	≤1500	156	144	144	145	144	122	158	143	152	136
pH	6.5-8.5	7.7	7.8	7.8	7.8	7.8	7.7	7.9	7.9	7.9	7.6
Turbidity (NTU)	≤5	0.99	1.35	1.07	1.67	1.30	1.13	0.86	1.43	0.80	1.48
Colour – Apparent (PtCo)	≤15	9	12	9	14	11	10	9	12	6	12
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.35	0.30	0.25	0.40	0.60	0.35	0.25	0.25	0.30	0.35
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 08th June 2026

Table: Average water quality for Kampala Water during the period running 01st June - 07th June 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Kabowa Village	Katale Lunya	Busabala - Kirinda C	Busabala Road, Kibiri TC	Kabakanjjagala Road	Nsambya Hospital	Bugolobi Sewerage Works	Nakasero Primary School	Makerere Kivulu	Nakawa Market
Electrical Conductivity (µs/cm)	≤1500	138	140	140	139	148	126	144	141	126	144
pH	6.5-8.5	7.4	7.6	7.6	7.7	7.8	7.9	7.8	7.8	7.8	7.8
Turbidity (NTU)	≤5	1.59	1.52	1.27	1.14	1.12	1.43	1.60	1.62	1.91	1.43
Colour – Apparent (PtCo)	≤15	14	12	13	14	10	15	15	15	13	13
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.30	0.30	0.30	0.25	0.45	0.30	0.45	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by: