

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 20th July 2026

Table: Average water quality for Kampala Water during the period running 13th July - 19th July 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Ziranumbu Booster	Gangu Booster	Ntenjeru Trading Center	Kisoga Trading Center	Ggonve Trading Center	Katosi Trading Center	Ngombere Trading Center	Kasokoso Community PSP	Bugolobi Hospital	Kinawataka Police Post
Electrical Conductivity (µs/cm)	≤1500	124	124	93	93	93	93	93	133	126	135
pH	6.5-8.5	7.4	7.5	7.4	7.3	7.3	7.4	7.4	7.1	7.2	7.2
Turbidity (NTU)	≤5	1.37	1.89	0.31	0.32	0.36	0.34	0.32	1.17	1.59	1.40
Colour – Apparent (PtCo)	≤15	10	5	2	2	3	3	2	0	7	9
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.65	0.70	0.83	0.82	0.79	0.82	0.79	0.40	0.40	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 20th July 2026

Table: Average water quality for Kampala Water during the period running 13th July - 19th July 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Bukoto White Flats	Kulambiro Pal & Lisa School	Ntinda New Market	Kisenyi II Kakajjo Zone	Aqua Coolers Ltd - 7th Street	Kamwokya Community	Green Hill Academy Kibuli	Kisugu Police Station	Bunamwaya Ngobe	Katale Lunya
Electrical Conductivity (µs/cm)	≤1500	135	125	127	119	126	121	126	121	127	125
pH	6.5-8.5	7.3	7.2	7.2	7.2	7.2	7.1	7.1	7.2	8.0	7.0
Turbidity (NTU)	≤5	1.47	1.48	1.18	1.50	1.05	1.84	1.96	1.47	0.84	0.81
Colour – Apparent (PtCo)	≤15	4	14	9	8	9	3	9	4	0	0
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.40	0.40	0.40	0.40	0.45	0.40	0.40	0.40	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by: