

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 22nd June 2026

Table: Average water quality for Kampala Water during the period running 15th June – 21st June 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Aqua Coolers Ltd - 7th Street	Centenary Park Booster	Kamwokya Community	Namayiba Bus Terminal	Sixth Street NWSC Offices	Uganda Railway Corporation H/Q	Kabakanjjagala Road	Kisenyi II Kakajjo Zone	Ndeeba Kasumba Zone	Namasuba Para Zone
Electrical Conductivity (µs/cm)	≤1500	136	132	134	128	136	129	129	133	114	118
pH	6.5-8.5	7.6	7.7	7.8	7.8	7.8	7.8	7.9	7.9	7.8	7.9
Turbidity (NTU)	≤5	1.85	1.08	0.67	1.09	1.14	1.43	1.10	0.86	1.22	0.90
Colour – Apparent (PtCo)	≤15	15	10	14	14	9	15	11	13	7	1
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.50	0.40	0.30	0.45	0.60	0.40	0.40	0.25	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 22nd June 2026

Table: Average water quality for Kampala Water during the period running 15th June – 21st June 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Mutundwe PAPSCA	Nyanama Trading Center	Nakasero Booster	Sonde Village	Mukono Bukasa Buyigi Estate Farm	Nansana Market	Namamve Booster	Namityango Trading Center	Namusera Trading Center	Busujja Trading Center
Electrical Conductivity (µs/cm)	≤1500	104	126	136	101	104	134	104	103	135	216
pH	6.5-8.5	7.8	7.8	7.9	7.9	7.7	7.9	7.9	7.9	7.9	7.0
Turbidity (NTU)	≤5	0.65	1.64	0.67	0.90	1.30	1.60	1.55	1.39	1.64	1.29
Colour – Apparent (PtCo)	≤15	0	10	2	6	5	9	11	10	7	0
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.20	0.40	0.35	0.30	0.30	0.60	0.40	0.30	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by: