

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 27th July 2026

Table: Average water quality for Kampala Water during the period running 20th July - 26th July 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Kyebando Ring Road SV	St. Paul's C.O.U Kyebando	Kisoga Trading Center	Ngombere Trading Center	Arua Park	Bwaise Mayinja Zone	United Christian Center Church - Kikoni	Nakulabye Market	Kawempe Mbogo Islamic P/S	Mawanda Road - Denaro Apartment
Electrical Conductivity (µs/cm)	≤1500	125	115	93	93	126	125	129	129	126	129
pH	6.5-8.5	6.7	6.7	7.2	7.2	7.3	7.4	7.5	7.5	7.2	7.1
Turbidity (NTU)	≤5	1.43	1.14	0.23	0.33	1.24	0.55	1.20	1.01	0.74	1.34
Colour – Apparent (PtCo)	≤15	11	2	0	0	6	0	0	0	1	12
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.35	0.40	0.35	0.30	0.40	0.30	0.35	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 27th July 2026

Table: Average water quality for Kampala Water during the period running 20th July - 26th July 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Luzira Market	Kabalega Crescent - Luzira	Naalya L.C. 1	Namugongo Jjanda	Kijabijjo Trading Center	Green Hill Academy Buwate	Ericsson House Nakasero	American Embassy Nsambya	Namuwongo Godown	Kyebando Central Zone
Electrical Conductivity (µs/cm)	≤1500	129	129	104	104	103	104	125	121	131	104
pH	6.5-8.5	7.1	7.1	7.3	7.6	7.6	7.7	6.7	6.7	6.7	6.7
Turbidity (NTU)	≤5	0.62	0.89	0.80	0.50	0.52	0.68	1.39	1.34	0.71	1.37
Colour – Apparent (PtCo)	≤15	0	3	0	0	0	0	9	7	2	2
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.35	0.30	0.30	0.35	0.35	0.30	0.40	0.45	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by: