

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 06th July 2026

Table: Average water quality for Kampala Water during the period running 29th June - 05th July 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Kyebando Nsooba	Luteete Trading Center	Kalerwe Market Lower Wing	United Christian Center Church - Kikoni	Shell at Grand Imperial Hotel	Salaama Road	Bweyogerere Market	Kireka Kamuli	Kirinya Bukasa	Biina Catholic Church – P/S
Electrical Conductivity (µs/cm)	≤1500	137	92	123	119	122	120	124	124	124	124
pH	6.5-8.5	7.4	7.3	7.3	7.4	7.3	7.4	7.3	7.3	7.2	7.1
Turbidity (NTU)	≤5	1.68	1.96	1.53	1.91	1.49	1.94	1.14	1.50	1.21	1.08
Colour – Apparent (PtCo)	≤15	11	12	8	10	12	14	4	8	4	4
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.25	0.35	0.40	0.55	0.30	0.35	0.30	0.20	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 06th July 2026

Table: Average water quality for Kampala Water during the period running 29th June - 05th July 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Bat Valley Primary School	Kanjokya Street SV	Namuwongo Market	Kiseka market	Bwaise Washing Bay	Lungujja - Kosovo	Namungoona Market	Mengo Bulange	Rubaga Cathedral Diocesan Office	Kyambogo Primary School
Electrical Conductivity (µs/cm)	≤1500	122	116	117	116	112	123	127	123	121	123
pH	6.5-8.5	7.2	7.3	7.3	7.3	7.3	7.3	7.2	7.3	7.2	7.2
Turbidity (NTU)	≤5	1.60	1.87	1.69	1.78	1.81	1.24	0.77	1.29	1.42	1.62
Colour – Apparent (PtCo)	≤15	10	13	14	12	13	13	5	6	8	10
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.35	0.60	0.45	0.30	0.40	0.30	0.30	0.35	0.40	0.35
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Ag. Sen. Manager Quality Assurance – KW

Approved by: