

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 03rd September 2026

Table: Average water quality for Kampala Water during the period running 24th August - 30th August 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Kabalagala Market	Nsambya Sisters	Bwaise Kusatu	Rubaga Kabuusu	Naalya LC1	GreenHill Academy Buwate	Maganjo Nalunya	Speke Hotel	Ntinda New Market	Nsambya Hospital
Electrical Conductivity (µs/cm)	≤1500	141	152	144	150	142	101	144	141	103	152
pH	6.5-8.5	7.4	6.7	6.8	6.8	7.4	7.2	7.5	7.4	7.0	6.7
Turbidity (NTU)	≤5	0.71	1.54	1.69	1.83	0.67	0.41	0.51	0.72	1.86	1.54
Colour – Apparent (PtCo)	≤15	2	12	9	11	3	2	3	2	7	12
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.25	0.35	0.25	0.35	0.30	0.30	0.20	0.30	0.25
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.

Wanyera Julius

Wanyera Julius
Ag.Principal Quality Control Officer – KW

Written by:

Enos Malambala

Enos Malambala
Senior Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 03rd September 2026

Table: Average water quality for Kampala Water during the period running 24th August - 30th August 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Rubaga Bulwa	Kasubi Market	Kamokya Market	Matuga Trading Centre	Gayaza Trading Centre	Kulambiro Tuba Zone	Buddonian Zone Kisenyi	Namungoona Market	Uganda Golf Club	Kawanda Trading Centre
Electrical Conductivity (µs/cm)	≤1500	151	142	150	122	94	140	143	149	147	148
pH	6.5-8.5	6.8	7.2	7.2	7.6	6.7	7.0	7.1	7.0	6.9	7.0
Turbidity (NTU)	≤5	2.80	2.01	0.67	1.22	0.81	0.99	1.54	1.18	1.00	0.69
Colour – Apparent (PtCo)	≤15	13	13	12	11	10	5	10	11	6	8
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.30	0.25	0.30	0.30	0.35	0.50	0.20	0.35	0.35
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physiochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.

Wanyera Julius

Wanyera Julius
Ag. Principal Quality Control Officer – KW

Written by:

Enos Malambala

Enos Malambala
Senior Manager Quality Assurance – KW

Approved by: