

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 08th September 2026

Table: Average Water quality for Kampala Water during the period running 31st August - 06th September 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Jomayi Estates Nabusugwe	Lungujja Makamba	Salaama Road	Nakawa Market	Bwaise Hppy Hours	Speke Resort Munyonyo	Kitukutwe Trading Centre	Katanga Mulago	Ggaba Seminary	Namboole Trading Cente
Electrical Conductivity (µs/cm)	≤1500	103	137	140	148	146	151	103	147	151	148
pH	6.5-8.5	7.7	6.7	7.0	6.8	7.1	6.7	7.7	7.0	6.9	6.8
Turbidity (NTU)	≤5	0.79	1.57	0.80	1.50	1.29	1.29	0.63	1.05	1.90	1.19
Colour – Apparent (PtCo)	≤15	4	15	10	14	13	8	0	8	14	10
<i>Escherichia coli</i> (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.30	0.25	0.45	0.30	0.35	0.30	0.35	0.35
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.

Wanyera Julius

Wanyera Julius
Ag.Principal Quality Control Officer – KW

Written by:

Enos Malambala

Enos Malambala
Sen. Manager Quality Assurance – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 03rd September 2026

Table: Average water quality for Kampala Water during the period running 31st August - 06th September 2026

Parameter	National Standard For Potable Water	Monitoring Points									
		Joggo Trading Centre	Makindye Kizungu	Uganda Golf Club	Kitereddye Village	Old Kampala Police Barracks	Bunamwaya Kitebi	Nakulabye Market	St. Balikudembe Market	Kirinya Bukasa	Luzira Prisons
Electrical Conductivity (µs/cm)	≤1500	104	154	147	139	148	151	138	148	147	148
pH	6.5-8.5	7.7	6.6	6.9	7.0	7.0	6.8	6.8	7.0	6.9	7.9
Turbidity (NTU)	≤5	0.72	1.68	1.00	0.76	1.59	1.35	1.39	1.58	1.31	0.69
Colour – Apparent (PtCo)	≤15	4	14	6	6	11	8	12	13	11	15
<i>Escherichia coli</i> (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.45	0.30	0.35	0.30	0.35	0.30	0.30	0.30	0.30	0.35
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physicochemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.

Wanyera Julius

Wanyera Julius
Ag. Principal Quality Control Officer – KW

Written by:

Enos Malambala

Enos Malambala
Sen. Manager Quality Assurance – KW

Approved by: